

C.No.513/FSD/FPW/NOC/2025/513

FIRE SAFETY CERTIFICATE

EoDB Application No. : 204445

Dated: 16.07.2025

Certified that the Wiseman Higher Secondary School at No.2, Erikarai street, Velrampet, Puducherry comprised of two storeyed building owned / occupied by M/s. Wiseman Higher Secondary School have complied with the Fire Prevention and Fire Safety requirement in accordance with the Codes & Standards and inspected & examined by the officers of the Fire Service Department in the presence of Thiru. B.A. Chandramouli, Correspondent and that the building /Premises is fit for occupancy up to classes LKG to XII for the academic year 2025-2026 from the issue of this certificate in accordance with Codes & Standards and subject to compliance of specific conditions as appended:-

1. To comply fully with the National Building Code of India, 2016 (Part 4 – Fire and Life Safety) and Standards for the present occupancy of the building at the earliest.
2. The Fixed Fire Fighting Installations provided in the building are to be under proper Care & Maintenance as per the Codes & Standards and recorded in registers by employing (24X7) well trained Fire Fighting Crew/Guards.
3. Emergency / Quick Response Team (ERT/QRT) with the above crew along with other Staffs shall be constituted for responding immediately during emergencies for safe & speedy evacuation of the occupants and loss mitigation.
4. The occupant and fire load of the building shall be maintained properly.
5. The Electrical equipment/appliances are to be maintained as per Codes and Standards for the building.
6. To have a total Evacuation Plan / SOP for fire and other emergencies, scheduled Annual time Table / Calendar for Fire Safety Training to the staffs, Table Top Exercise, Mock drill and conduct the same under the supervision of the Fire Service Department.
7. The approved class of occupancy of the building shall not be altered.
8. The Setbacks on all sides, Corridors, Passages, Staircases, Entries and Exits shall always be free of any obstruction for easy movement during any emergency.
9. Any structural addition/alteration in the building shall be made with the prior approval of the Competent Authority and Fire Service Department.

Issued on 16.07.2025 at Puducherry.

(Handwritten signature)
 16/07/2025
 (K. ILANGO)
 DIVISIONAL FIRE OFFICER
 PUDUCHERRY

To

M/s. Wiseman Higher Secondary School,
 No. 2, Erikarai Street, Velrampet, Puducherry.



ATTESTED BY

(Handwritten signature)
 PRINCIPAL
 Wiseman Hr. Sec. School
 Velrampet, Mudaliarpet,
 Puducherry - 605 004.